

MARKET PARTICIPANTS - NORTHERN IRELAND TRANSMISSION LOSS ADJUSTMENT FACTORS 2013/14																											
NI Transmission-Connected Generation Station	Unit Identifier		Connected at	Month																							
				October 2013		November 2013		December 2013		January 2014		February 2014		March 2014		April 2014		May 2014		June 2014		July 2014		August 2014		September 2014	
	SO	MO		Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night
Ballylumford	B4	GU_500282	Ballylumford 275 kV	0.996	0.993	0.996	0.994	0.998	0.995	0.999	0.997	0.998	0.997	0.997	0.997	0.995	0.992	0.991	0.988	0.996	0.996	0.996	0.998	0.997	0.993	0.993	0.989
Ballylumford (deregistered GU_500110)	B5	GU_500281	Ballylumford 275 kV	0.996	0.993	0.996	0.994	0.998	0.995	0.999	0.997	0.998	0.997	0.997	0.997	0.995	0.992	0.991	0.988	0.996	0.996	0.996	0.998	0.997	0.993	0.993	0.989
Ballylumford (deregistered GU_500120)	B6	GU_500280	Ballylumford 275 kV	0.996	0.993	0.996	0.994	0.998	0.995	0.999	0.997	0.998	0.997	0.997	0.997	0.995	0.992	0.991	0.988	0.996	0.996	0.996	0.998	0.997	0.993	0.993	0.989
Ballylumford	BGT1	GU_500150	Ballylumford 110 kV	0.994	0.992	0.994	0.993	0.996	0.995	0.997	0.996	0.997	0.997	0.996	0.996	0.994	0.992	0.991	0.988	0.995	0.996	0.995	0.997	0.995	0.993	0.992	0.989
Ballylumford	BGT2	GU_500160	Ballylumford 110 kV	0.994	0.992	0.994	0.993	0.996	0.995	0.997	0.996	0.997	0.997	0.996	0.996	0.994	0.992	0.991	0.988	0.995	0.996	0.995	0.997	0.995	0.993	0.992	0.989
Ballylumford	B10	GU_500140	Ballylumford 110 kV	0.994	0.992	0.994	0.993	0.996	0.995	0.997	0.996	0.997	0.997	0.996	0.996	0.994	0.992	0.991	0.988	0.995	0.996	0.995	0.997	0.995	0.993	0.992	0.989
Ballylumford Combined	B20, B21, B22	GU_500130/131	Ballylumford 275 kV	0.996	0.993	0.996	0.994	0.998	0.995	0.999	0.997	0.998	0.997	0.997	0.997	0.995	0.992	0.991	0.988	0.996	0.996	0.996	0.998	0.997	0.993	0.993	0.989
Coolkeeragh	C30	GU_500040	Coolkeeragh 275/110 kV	0.992	0.987	0.992	0.988	0.994	0.991	0.995	0.991	0.994	0.992	0.993	0.992	0.991	0.988	0.987	0.984	0.994	0.993	0.992	0.993	0.992	0.988	0.989	0.989
Coolkeeragh	CGT8	GU_500170	Coolkeeragh 110 kV	0.99	0.986	0.991	0.986	0.993	0.989	0.994	0.989	0.989	0.993	0.991	0.991	0.989	0.987	0.986	0.983	0.993	0.993	0.99	0.992	0.99	0.987	0.987	0.987
Kilroot	K1	GU_500822	Kilroot 275 kV	0.996	0.993	0.996	0.993	0.998	0.995	0.999	0.996	0.999	0.997	0.997	0.997	0.995	0.992	0.992	0.988	0.996	0.995	0.996	0.997	0.996	0.992	0.993	0.989
Kilroot	K2	GU_500823	Kilroot 275 kV	0.996	0.993	0.996	0.993	0.998	0.995	0.999	0.996	0.999	0.997	0.997	0.997	0.995	0.992	0.992	0.988	0.996	0.995	0.996	0.997	0.996	0.992	0.993	0.989
Kilroot	KGT1	GU_500824	Kilroot 275 kV	0.996	0.993	0.996	0.993	0.998	0.995	0.999	0.996	0.999	0.997	0.997	0.997	0.995	0.992	0.992	0.988	0.996	0.995	0.996	0.997	0.996	0.992	0.993	0.989
Kilroot	KGT2	GU_500825	Kilroot 275 kV	0.996	0.993	0.996	0.993	0.998	0.995	0.999	0.996	0.999	0.997	0.997	0.997	0.995	0.992	0.992	0.988	0.996	0.995	0.996	0.997	0.996	0.992	0.993	0.989
Kilroot	KGT3	GU_500820	Kilroot 275 kV	0.996	0.993	0.996	0.993	0.998	0.995	0.999	0.996	0.999	0.997	0.997	0.997	0.995	0.992	0.992	0.988	0.996	0.995	0.996	0.997	0.996	0.992	0.993	0.989
Kilroot	KGT4	GU_500821	Kilroot 275 kV	0.996	0.993	0.996	0.993	0.998	0.995	0.999	0.996	0.999	0.997	0.997	0.997	0.995	0.992	0.992	0.988	0.996	0.995	0.996	0.997	0.996	0.992	0.993	0.989
Moyle (Auchencrosh)*	M	GU_500200	Auchencrosh 275 kV	0.989	0.987	0.989	0.988	0.991	0.989	0.992	0.991	0.991	0.991	0.99	0.991	0.989	0.987	0.984	0.983	0.991	0.992	1.05	1.053	0.993	0.99	0.986	0.983

NI Distribution-Connected Generation Station	Unit Identifier		Connected/Embedded at	Month																							
				October 2013		November 2013		December 2013		January 2014		February 2014		March 2014		April 2014		May 2014		June 2014		July 2014		August 2014		September 2014	
	SO	MO		Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night
Altahullion (1)	Wind Farm	GU_500210	Limavady 110 kV	0.998	0.991	0.999	0.992	1.001	0.994	1.003	0.996	1.002	0.997	0.999	0.996	0.996	0.995	0.992	0.991	0.999	0.999	0.996	0.996	0.996	0.993	0.994	0.992
Altahullion (2)	Wind Farm	GU_500211	Limavady 110 kV	0.998	0.991	0.999	0.992	1.001	0.994	1.003	0.996	1.002	0.997	0.999	0.996	0.996	0.995	0.992	0.991	0.999	0.999	0.996	0.996	0.996	0.993	0.994	0.992
Callagheen	Wind Farm	GU_500020	Enniskillen 110 kV	0.997	0.987	0.998	0.988	1.001	0.99	1.005	0.992	1.003	0.993	0.998	0.992	0.995	0.993	0.991	0.989	0.997	0.994	0.994	0.991	0.994	0.99	0.993	0.989
Crockagarran	Wind Farm	GU_501050	Dungannon 110 kV	1	0.994	1	0.995	1.002	0.997	1.004	0.998	1.003	0.999	1	0.998	0.998	0.994	0.995	0.991	1	0.997	0.998	0.998	0.999	0.994	0.996	0.991
Hunter's Hill	Wind Farm	GU_501040	Omagh 110 kV	0.993	0.986	0.994	0.986	0.996	0.989	0.999	0.99	0.998	0.991	0.994	0.99	0.992	0.988	0.988	0.984	0.994	0.991	0.991	0.989	0.991	0.986	0.989	0.984
Lendrums Bridge (1)	Wind Farm	GU_500260	Omagh 110 kV	0.993	0.986	0.994	0.986	0.996	0.989	0.999	0.99	0.998	0.991	0.994	0.99	0.992	0.988	0.988	0.984	0.994	0.991	0.991	0.989	0.991	0.986	0.989	0.984
Lendrums Bridge (1)	Wind Farm	GU_500220	Omagh 110 kV	0.993	0.986	0.994	0.986	0.996	0.989	0.999	0.99	0.998	0.991	0.994	0.99	0.992	0.988	0.988	0.984	0.994	0.991	0.991	0.989	0.991	0.986	0.989	0.984
Mantlin Limited	Wind Farm	GU_500270	Aghyoule 110 kV	0.993	0.981	0.994	0.982	0.996	0.985	1.001	0.987	0.998	0.987	0.994	0.986	0.99	0.995	0.986	0.992	0.992	0.994	0.988	0.986	0.989	0.989	0.988	0.992
Snugborough	Wind Farm	GU_500180	Aghyoule 110 kV	0.993	0.981	0.994	0.982	0.996	0.985	1.001	0.987	0.998	0.987	0.994	0.986	0.99	0.995	0.986	0.992	0.992	0.994	0.988	0.986	0.989	0.989	0.988	0.992
Tappaghan	Wind Farm	GU_500010	Omagh 110 kV	0.993	0.986	0.994	0.986	0.996	0.989	0.999	0.99	0.998	0.991	0.994	0.99	0.992	0.988	0.988	0.984	0.994	0.991	0.991	0.989	0.991	0.986	0.989	0.984
Slieve Divena	Wind Farm	GU_500740	Omagh 110 kV	0.993	0.986	0.994	0.986	0.996	0.989	0.999	0.99	0.998	0.991	0.994	0.99	0.992	0.988	0.988	0.984	0.994	0.991	0.991	0.989	0.991	0.986	0.989	0.984
Garves	Wind Farm	GU_500720	Coleraine 110 kV	1.003	0.995	1.003	0.995	1.006	0.998	1.008	0.999	1.007	1.001	1.003	1	1	0.998	0.996	0.994	1.003	1.002	1	0.999	1	0.997	0.998	0.994
Gruig	Wind Farm	GU_500790	Coleraine 110 kV	1.003	0.995	1.003	0.995	1.006	0.998	1.008	0.999	1.007	1.001	1.003	1	1	0.998	0.996	0.994	1.003	1.002	1	0.999	1	0.997	0.998	0.994
Screggagh	Wind Farm	GU_501120	Omagh 110 kV	0.993	0.986	0.994	0.986	0.996	0.989	0.999	0.99	0.998	0.991	0.994	0.99	0.992	0.988	0.988	0.984	0.994	0.991	0.991	0.989	0.991	0.986	0.989	0.984
Contour global		GU_500900	Lisburn 110	1.002	0.997	1.002	0.998	1.004	1	1.006	1.001	1.005	1.002	1.003	1.001	1	0.997	0.997	0.993	1.001	1	1.001	1.001	1.001	0.998	0.998	0.994
Contour global		GU_500901	Lisburn 110	1.002	0.997	1.002	0.998	1.004	1	1.006	1.001	1.005	1.002	1.003	1.001	1	0.997	0.997	0.993	1.001	1	1.001	1.001	1.001	0.998	0.998	0.994
Contour global		GU_500902	Lisburn 110	1.002	0.997	1.002	0.998	1.004	1	1.006	1.001	1.005	1.002	1.003	1.001	1	0.997	0.997	0.993	1.001	1	1.001	1.001	1.001	0.998	0.998	0.994
Contour global		GU_500903	Lisburn 110	1.002	0.997	1.002	0.998	1.004	1	1.006	1.001	1.005	1.002	1.003	1.001	1	0.997	0.997	0.993	1.001	1	1.001	1.001	1.001	0.998	0.998	0.994
iPower AGU	AGU (PPMG)		NA	1.001	0.995	1.001	0.996	1.003	0.998	1.005	1.000	1.004	1.001	1.002	1.000	0.999	0.997	0.996	0.993	1.001	1.000	0.999	1.000	1.000	0.997	0.997	0.994
Curryfree	Wind Farm	GU_501150	Lisaghmore 110 kV	0.992	0.987	0.992	0.988	0.995	0.99	0.996	0.991	0.995	0.992	0.993	0.992	0.991	0.99	0.988	0.986	0.995	0.995	0.992	0.993	0.991	0.989	0.989	0.987
Slieve Kirk	Wind Farm	GU_501160	Killymallaght 110 kV	0.991	0.985	0.991	0.986	0.994	0.988	0.995	0.989	0.994	0.991	0.992	0.99	0.99	0.988	0.986	0.984	0.993	0.993	0.99	0.991	0.99	0.987	0.987	0.985
Crighshane	Wind Farm	GU_501180	Magherakeel 110 kV	0.983	0.975	0.983	0.976	0.986	0.978	0.988	0.98	0.987	0.981	0.984	0.98	0.981	0.983	0.978	0.979	0.983	0.984	0.98	0.979	0.981	0.979	0.979	0.98
Church Hill	Wind Farm	GU_501170	Magherakeel 110 kV	0.983	0.975	0.983	0.976	0.986	0.978	0.988	0.98	0.987	0.981	0.984	0.98	0.981	0.983	0.978	0.979	0.983	0.984	0.98	0.979	0.981	0.979	0.979	0.98
Carrickatane	Wind Farm	GU_501190	Killymallaght 110 kV	0.991	0.985	0.991	0.986	0.994	0.988	0.995	0.989	0.994	0.991	0.992	0.99	0.99	0.988	0.986	0.984	0.993	0.993	0.99	0.991	0.99	0.987	0.987	0.985
Carn Hill	Wind Farm	GU_501210	Carnmoney 110 kV	1.001	0.997	1.001	0.998	1.004	1	1.005	1.001	1.004	1.002	1.002	1.001	1	0.999	0.996	0.995	1.001	1.001	1.001	1.001	1.001	0.998	0.998	0.996