

MARKET PARTICIPANTS - NORTHERN IRELAND TRANSMISSION LOSS ADJUSTMENT FACTORS 2012/13																											
NI Transmission-Connected Generation Station	Unit Identifier		Connected at	Month																							
	SO	MO		October 2012		November 2012		December 2012		January 2013		February 2013		March 2013		April 2013		May 2013		June 2013		July 2013		August 2013		September 2013	
				Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night
Ballylumford	B4	GU_500100	Ballylumford 275 kV	0.997	1.000	0.994	0.998	0.994	1.009	0.993	0.998	0.993	0.999	0.994	0.998	0.993	0.996	0.995	0.998	0.990	0.991	0.997	0.997	0.991	0.994	0.991	0.994
Ballylumford (deregistered GU_500110)	B5	GU_500281	Ballylumford 275 kV	0.997	1.000	0.994	0.998	0.994	1.009	0.993	0.998	0.993	0.999	0.994	0.998	0.993	0.996	0.995	0.998	0.990	0.991	0.997	0.997	0.991	0.994	0.991	0.994
Ballylumford (deregistered GU_500120)	B6	GU_500280	Ballylumford 275 kV	0.997	1.000	0.994	0.998	0.994	1.009	0.993	0.998	0.993	0.999	0.994	0.998	0.993	0.996	0.995	0.998	0.990	0.991	0.997	0.997	0.991	0.994	0.991	0.994
Ballylumford	BGT1	GU_500150	Ballylumford 110 kV	0.995	1.000	0.993	0.997	0.993	1.009	0.993	0.999	0.993	0.999	0.994	0.998	0.993	0.996	0.995	0.998	0.990	0.991	0.997	0.998	0.991	0.994	0.991	0.994
Ballylumford	BGT2	GU_500160	Ballylumford 110 kV	0.995	1.000	0.993	0.997	0.993	1.009	0.993	0.999	0.993	0.999	0.994	0.998	0.993	0.996	0.995	0.998	0.990	0.991	0.997	0.998	0.991	0.994	0.991	0.994
Ballylumford	B10	GU_500140	Ballylumford 110 kV	0.995	1.000	0.993	0.997	0.993	1.009	0.993	0.999	0.993	0.999	0.994	0.998	0.993	0.996	0.995	0.998	0.990	0.991	0.997	0.998	0.991	0.994	0.991	0.994
Ballylumford Combined	B20, B21, B22	GU_500130/131	Ballylumford 275 kV	0.997	1.000	0.994	0.998	0.994	1.009	0.993	0.998	0.993	0.999	0.994	0.998	0.993	0.996	0.995	0.998	0.990	0.991	0.997	0.997	0.991	0.994	0.991	0.994
Coolkeeragh	C30	GU_500040	Coolkeeragh 275/110 kV	0.994	0.996	0.991	0.993	0.988	0.996	0.987	0.992	0.988	0.994	0.988	0.993	0.989	0.990	0.990	0.990	0.993	0.990	0.991	0.989	0.987	0.987	0.986	0.989
Coolkeeragh	CGT8	GU_500170	Coolkeeragh 110 kV	0.993	0.995	0.990	0.992	0.987	0.993	0.986	0.991	0.987	0.992	0.987	0.991	0.987	0.988	0.988	0.987	0.992	0.989	0.989	0.987	0.985	0.985	0.985	0.987
Kilroot	K1	GU_500060	Kilroot 275 kV	0.996	0.999	0.994	0.997	0.994	1.007	0.993	0.998	0.993	0.998	0.993	0.998	0.993	0.995	0.994	0.997	0.991	0.991	0.997	0.996	0.991	0.993	0.990	0.993
Kilroot	K2	GU_500070	Kilroot 275 kV	0.996	0.999	0.994	0.997	0.994	1.007	0.993	0.998	0.993	0.998	0.993	0.998	0.993	0.995	0.994	0.997	0.991	0.991	0.997	0.996	0.991	0.993	0.990	0.993
Kilroot	KGT1	GU_500080	Kilroot 275 kV	0.996	0.999	0.994	0.997	0.994	1.007	0.993	0.998	0.993	0.998	0.993	0.998	0.993	0.995	0.994	0.997	0.991	0.991	0.997	0.996	0.991	0.993	0.990	0.993
Kilroot	KGT2	GU_500090	Kilroot 275 kV	0.996	0.999	0.994	0.997	0.994	1.007	0.993	0.998	0.993	0.998	0.993	0.998	0.993	0.995	0.994	0.997	0.991	0.991	0.997	0.996	0.991	0.993	0.990	0.993
Kilroot	KGT3	GU_500820	Kilroot 275 kV	0.996	0.999	0.994	0.997	0.994	1.007	0.993	0.998	0.993	0.998	0.993	0.998	0.993	0.995	0.994	0.997	0.991	0.991	0.997	0.996	0.991	0.993	0.990	0.993
Kilroot	KGT4	GU_500821	Kilroot 275 kV	0.996	0.999	0.994	0.997	0.994	1.007	0.993	0.998	0.993	0.998	0.993	0.998	0.993	0.995	0.994	0.997	0.991	0.991	0.997	0.996	0.991	0.993	0.990	0.993
Moyle (Auchencrosh)*	M	GU_500200	Auchencrosh 275 kV	0.991	0.994	0.990	0.991	0.990	0.996	0.989	0.991	0.988	0.992	0.987	0.991	0.987	0.992	0.988	0.994	0.984	0.989	0.991	0.995	0.989	0.994	0.989	0.993
NI Distribution-Connected Generation Station	Unit Identifier		Connected/Embedded at	Month																							
	SO	MO		October 2012		November 2012		December 2012		January 2013		February 2013		March 2013		April 2013		May 2013		June 2013		July 2013		August 2013		September 2013	
				Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night	Day	Night
Altahullion (1)	Wind Farm	GU_500210	Limavady 110 kV	0.998	0.998	0.996	0.996	0.994	1.003	0.992	0.995	0.993	0.997	0.993	0.996	0.992	0.991	0.992	0.991	0.994	0.989	0.994	0.990	0.988	0.987	0.988	0.989
Altahullion (2)	Wind Farm	GU_500211	Limavady 110 kV	0.998	0.998	0.996	0.996	0.994	1.003	0.992	0.995	0.993	0.997	0.993	0.996	0.992	0.991	0.992	0.991	0.994	0.989	0.994	0.990	0.988	0.987	0.988	0.989
Callagheen	Wind Farm	GU_500020	Enniskillen 110 kV	1.004	1.002	1.002	0.999	0.999	1.007	0.997	0.997	0.997	0.999	0.997	0.998	0.994	0.992	0.995	0.993	0.995	0.988	0.997	0.991	0.991	0.988	0.990	0.990
Crockagarran	Wind Farm	GU_501050	Dungannon 110 kV	1.002	1.002	1.000	1.000	0.998	1.012	0.997	1.000	0.997	1.001	0.997	1.000	0.996	0.996	0.997	0.997	0.995	0.992	0.999	0.996	0.994	0.994	0.993	0.994
Hunter's Hill	Wind Farm	GU_501040	Omagh 110 kV	1.000	1.000	0.998	0.997	0.994	1.001	0.993	0.994	0.993	0.996	0.993	0.995	0.991	0.990	0.992	0.990	0.992	0.986	0.993	0.989	0.988	0.986	0.987	0.987
Lendrums Bridge (1)	Wind Farm	GU_500260	Omagh 110 kV	1.000	1.000	0.998	0.997	0.994	1.001	0.993	0.994	0.993	0.996	0.993	0.995	0.991	0.990	0.992	0.990	0.992	0.986	0.993	0.989	0.988	0.986	0.987	0.987
Lendrums Bridge (1)	Wind Farm	GU_500220	Omagh 110 kV	1.000	1.000	0.998	0.997	0.994	1.001	0.993	0.994	0.993	0.996	0.993	0.995	0.991	0.990	0.992	0.990	0.992	0.986	0.993	0.989	0.988	0.986	0.987	0.987
Mantlin Limited	Wind Farm	GU_500270	Aghyoule 110 kV	1.001	0.999	0.999	0.996	0.996	1.001	0.994	0.994	0.995	0.995	0.994	0.995	0.991	0.989	0.992	0.990	0.992	0.984	0.994	0.988	0.987	0.985	0.987	0.986
Snugborough	Wind Farm	GU_500180	Aghyoule 110 kV	1.001	0.999	0.999	0.996	0.996	1.001	0.994	0.994	0.995	0.995	0.994	0.995	0.991	0.989	0.992	0.990	0.992	0.984	0.994	0.988	0.987	0.985	0.987	0.986
Tappaghan	Wind Farm	GU_500010	Omagh 110 kV	1.000	1.000	0.998	0.997	0.994	1.001	0.993	0.994	0.993	0.996	0.993	0.995	0.991	0.990	0.992	0.990	0.992	0.986	0.993	0.989	0.988	0.986	0.987	0.987
Slieve Divena	Wind Farm	GU_500740	Omagh 110 kV	1.000	1.000	0.998	0.997	0.994	1.001	0.993	0.994	0.993	0.996	0.993	0.995	0.991	0.990	0.992	0.990	0.992	0.986	0.993	0.989	0.988	0.986	0.987	0.987
Garves	Wind Farm	GU_500720	Coleraine 110 kV	1.001	1.000	0.999	0.998	0.998	1.009	0.995	0.998	0.996	0.999	0.996	0.999	0.994	0.994	0.995	0.994	0.996	0.991	0.997	0.993	0.991	0.990	0.990	0.991
Gruig	Wind Farm	GU_500790	Coleraine 110 kV	1.001	1.000	0.999	0.998	0.998	1.009	0.995	0.998	0.996	0.999	0.996	0.999	0.994	0.994	0.995	0.994	0.996	0.991	0.997	0.993	0.991	0.990	0.990	0.991
Screggagh	Wind Farm	GU_501120	Omagh 110 kV	1.000	1.000	0.998	0.997	0.994	1.001	0.993	0.994	0.993	0.996	0.993	0.995	0.991	0.990	0.992	0.990	0.992	0.986	0.993	0.989	0.988	0.986	0.987	0.987
Contour global		GU_500900	Lisburn 110	1.002	1.004	1.000	1.002	1.000	1.017	0.999	1.003	0.999	1.003	0.999	1.002	0.997	0.999	0.999	1.001	0.995	0.994	1.001	1.000	0.995	0.997	0.995	0.997
Contour global		GU_500901	Lisburn 110	1.002	1.004	1.000	1.002	1.000	1.017	0.999	1.003	0.999	1.003	0.999	1.002	0.997	0.999	0.999	1.001	0.995	0.994	1.001	1.000	0.995	0.997	0.995	0.997
Contour global		GU_500902	Lisburn 110	1.002	1.004	1.000	1.002	1.000	1.017	0.999	1.003	0.999	1.003	0.999	1.002	0.997	0.999	0.999	1.001	0.995	0.994	1.001	1.000	0.995	0.997	0.995	0.997
Contour global		GU_500903	Lisburn 110	1.002	1.004	1.000	1.002	1.000	1.017	0.999	1.003	0.999	1.003	0.999	1.002	0.997	0.999	0.999	1.001	0.995	0.994	1.001	1.000	0.995	0.997	0.995	0.997
iPower AGU	AGU (PPMG)	NA		1.001	1.003	1.000	1.001	0.999	1.014	0.997	1.001	0.998	1.00														