

**Other System Charges (OSC) Trip Report
2015/2016**

Date	Unit	MW Lost	Pre-incident [Hz]	Frequency Nadir [Hz]	Trip Type
02/10/2015 07:54	Ballylumford CCGT Unit 21 255 MW	168.924	49.991	49.796	Direct
08/10/2015 11:22	Coolkeeragh C30	374.442	50.062	49.672	Direct
18/10/2015 19:09	Moneypoint unit 2	172.56	50.03	49.90	Slow wind down
24/10/2015 21:34	Moneypoint unit 1	264.12	49.95	49.90	Fast wind down
15/11/2015 02:36	Coolkeeragh C30	273.313	49.983	49.735	Direct
06/11/2015 08:16	Moneypoint unit 1	187.96	49.97	49.85	Slow Wind-down trip
13/11/2015 11:59	West Offaly Power unit 4	154.02	50.06	49.78	Direct
13/11/2015 12:23	Moneypoint unit 1	140.34	50.06	49.92	Slow Wind-down trip
24/11/2015 13:22	Moneypoint unit 1	149.87	50.02	49.93	Slow Wind-down trip
25/11/2015 16:55	Moneypoint unit 1	281.40	49.98	49.94	Fast Wind-down Trip
25/11/2015 17:16	Tarbert unit 3	217.19	50.01	49.75	Fast Wind-down Trip
26/11/2015 18:22	Tarbert unit 3	174.65	50.03	49.82	Fast Wind-down Trip
29/11/2015 15:38	Great Island unit 4	130.15	50.05	49.83	Direct
02/12/2015 12:16	Moneypoint unit 3	137.25	49.94	49.87	Slow Wind-down trip
06/12/2015 12:18	Moneypoint unit 1	292.39	49.99	49.83	Fast Wind-down Trip
17/12/2015 17:39	Moneypoint unit 3	293.27	20.05	49.84	Fast Wind-down Trip
02/01/2015 08:36	Moneypoint unit 1	120.85	49.97	49.71	Direct
20/01/2016 16:01	WhiteGate unit 1	308.63	50.01	49.86	Slow Wind-down trip
15/01/2016 00:32	Kilroot Unit 1 260MW Oil/220MW Coal	149.405	50.04	49.744	Direct
20/01/2016 12:36	Coolkeeragh C30	164.736	49.90	49.798	Direct
18/02/2016 09:00	Moneypoint unit 1	227.64	50.04	49.86	Slow Wind-down trip
21/02/2016 15:29	Ballylumford CCGT Unit 22 255 MW	117.451	49.98	49.86	Direct
24/02/2016 05:53	Kilroot Unit 2 260MW Oil/220MW Coal	113.404	49.95	49.82	Direct
27/02/2016 09:36	Moneypoint unit 1	291.97	50.03	49.93	Fast Wind-down Trip