


THE NEED FOR ITC AND CONSTRAINTS


RENEWABLE GENERATION

RENEWABLE GENERATION INSTALLED CAPACITY 2005 - 2011



RENEWABLE GENERATION

PROJECTED WIND CONNECTIONS TO 2020 (MW)



DEVELOPER REQUIREMENTS

- **COMMON REQUESTS FROM DEVELOPERS:**
 - FIRM ACCESS QUANTITIES
 - TIMELINES OF TRANSMISSION WORKS
 - LIKELY CONSTRAINTS/CURTAILMENTS PRE AND POST NETWORK REINFORCEMENT

- **REQUIRED FOR DETAILED PROJECT FINANCIAL ANALYSIS**

SONI LICENCE


- **CONDITION 25 OF “LICENCE TO PARTICIPATE IN THE TRANSMISSION OF ELECTRICITY”**
- **OFFER OF TERMS FOR THE USE OF THE ALL-ISLAND TRANSMISSION NETWORK**

“On application by any eligible person, the Licensee shall offer to enter into a Use of System Agreement”
- **OFFER OF TERMS FOR CONNECTION TO THE ALL-ISLAND TRANSMISSION NETWORK**

RELATIONSHIPS


FOR DISTRIBUTION CONNECTED USERS

FOR TRANSMISSION CONNECTIONS- CONNECTION AGREEMENT BETWEEN SONI AND DEVELOPER




INCREMENTAL TRANSFER CAPABILITY METHODOLOGY

PRESENT NI NETWORK




CONSTRAINED REGION




GENERATION BY 2016

- **RENEWABLE:**
 - PRESENTLY 397.8 MW CONNECTED
 - OF WHICH 119 MW CONNECTED VIA SPECIAL PROTECTION SCHEME
 - FURTHER 512 MW WITH PLANNING APPROVAL
 - TOTAL OF 910MW OF RENEWABLE GENERATION CONNECTED BY 2016
- **CONVENTIONAL:**
 - NO PRESENT APPLICATIONS


GENERATION BY 2016




NI TRANSMISSION NETWORK DEVELOPMENT



SIMPLIFIED PROCESS




PROCESS – YEAR 1




GENERATOR	MEC	FAQ
A	10	10
B	15	10
C	20	0
D	15	0
E	30	30

PROCESS – YEAR 2



GENERATOR	MEC	FAQ
A	10	10
B	15	10
C	20	20
D	15	10
E	30	30

PROCESS – YEAR 3



GENERATOR	MEC	FAQ
A	10	10
B	15	15
C	20	20
D	15	10
E	30	30


NORTHERN IRELAND APPROACH

- **EACH GENERATOR TESTED AT FOUR DEMAND SCENARIOS:**
 - WINTER MAXIMUM
 - AUTUMN MAXIMUM
 - SUMMER MAXIMUM
 - SUMMER MINIMUM

- **CONTINGENCY ANALYSIS PERFORMED FOR EACH SEASON:**
 - N-1 AND N-DC FOR WINTER
 - N-1 FOR AUTUMN AND SUMMER
 - COOLKEERAGH-MAGHERAFELT DOUBLE CIRCUIT LOSS INCLUDED FOR ALL SEASONS

- **NEW GENERATION ACCOMMODATED BY THREE METHODS:**

NORTHERN IRELAND APPROACH



NORTHERN IRELAND APPROACH

- **EACH GENERATOR TESTED AT FOUR DEMAND SCENARIOS:**
 - WINTER MAXIMUM
 - AUTUMN MAXIMUM
 - SUMMER MAXIMUM
 - SUMMER MINIMUM
- **CONTINGENCY ANALYSIS PERFORMED FOR EACH SEASON:**
 - N-1 AND N-DC FOR WINTER
 - N-1 AND N-M-T FOR AUTUMN AND SUMMER
 - COOLKEERAGH-MAGHERAFELT DOUBLE CIRCUIT LOSS INCLUDED FOR ALL SEASONS
- **NEW GENERATION ACCOMMODATED BY THREE METHODS:**
 - BY DISPLACING EXISTING NI GENERATION
 - SENDING THE POWER TO RoI
 - SENDING THE POWER TO GB
- **IN TOTAL, 12 SETS OF CONTINGENCY STUDIES PERFORMED FOR EACH GENERATOR**

DISPATCH ASSUMPTIONS IN NI

- **EXISTING RENEWABLE GENERATION DISPATCHED AT 100% OUTPUT**
- **MOYLE TRANSFER BASED ON AVERAGE HISTORICAL FLOWS**
- **CONVENTIONAL GENERATION DISPATCHED ON A MERIT ORDER BASIS:**
 - **MINIMUM OF THREE MACHINES ON IN NORTHERN IRELAND**
 - **CONVENTIONAL PLANT DISPATCHED ON AN ALL-ISLAND BASIS**
- **NORTH-SOUTH TRANSFERS MAINTAINED WITHIN EXISTING LIMITS**
 - **330 MW EXPORT**
 - **260 MW IMPORT**

OUTPUT

GENERATOR	110kV NODE	MEC	2011		2012		2013	
			FAQ	NOTES	FAQ	NOTES	FAQ	NOTES
A	COLERAINE	20	10	Overloads on Coleraine-Kells 110kV circuit restricts FAQ	20	Transfer of windfarm to new cluster allows full FAQ	20	Full FAQ allocated
B	BALLYVALLAGH	30	30	Full FAQ allocated	30	Full FAQ allocated	30	Full FAQ allocated
C	OMAGH	25	0	No FAQ as there is no capacity on the existing 110/33kV TXs	5	Omagh TXs changed, FAQ limited by Omagh-Dungannon 110kV circuits	25	Completion of third Omagh-Dungannon 110kV circuit allows full FAQ
D	COLERAINE	20	0	No FAQ due to overloads on Coleraine-Kells 110kV circuit	10	Transfer of windfarm A to new cluster allows allocation of some FAQ	20	Completion of uprating on Coleraine-Kells 110kV circuit allows full FAQ
E	OMAGH	15	0	No FAQ as there is no capacity on the existing 110/33kV TXs	0	Overload on Omagh-Dungannon 110kV circuits	15	Completion of third Omagh-Dungannon 110kV circuit allows full FAQ

SUMMARY


- **512MW OF RENEWABLE GENERATION TO BE CONNECTED BY 2016**
- **SORTED INTO A QUEUE BASED ON PLANNING APPROVAL DATE**
- **EACH GENERATOR IN TURN SUBJECT TO COMPREHENSIVE N-1 AND N-DC ANALYSIS**
- **NETWORK REINFORCEMENTS BASED ON NIE's TIP**

Generator Output Reductions

Methodology

Methodology – Part One

- The worst case contingency for the NI transmission system is the loss of CPS – MAG 275kV Double Circuit. This methodology assumes that SONI will pre fault constrain to prevent overloads should this outage occur at any time. (the remaining network is modelled solid)




Methodology – Part One

- Load flow studies are carried out in Summer, Autumn/Spring and Winter (to take account of seasonal ratings). These studies identify how much generation can be connected to the Northern Ireland system before a network overload occurs i.e. by connecting proposed generators incrementally. The studies are carried out over a range of system load conditions for each season.
- The results are plotted and correlated to determine an equation that allows us to input into the Half hour constraints model.

Load flow studies from 2016 analysis

2016 ALLOWABLE WIND - ALL SEASONS



Methodology – Part Two

4. We determine how much **Network capacity** there is on the remaining transmission network to export power from the West to the East. (363MW of the 398MW installed in NI lies to the western side of the 3 remaining transmission lines).
5. A half-hour **Network Capacity** figure is calculated and used in the constraint model along with–
 - Half hour forecasted demand data
 - Forecasted wind profile (2008 base year)


When the forecasted Wind profile is higher than the Allowable wind in any half hour, then a constraint occurs.

Outcomes from Constraint model

- Constrained half hour wind profile
 - Quantity and Occurrence of constraints (half hour)
6. The half hours are counted and the percentage of time that wind needs to be constrained will be presented

Methodology – 2016 Constraints

- MAX = 205MW
- AVERAGE = 5MW



Constraints

- Constraints are applied on a pro rata basis across all nodes that contribute to the constraint. Pro Rata is based on MEC.
- No distinction has been made between controllable and non controllable wind. The figures are presented at a nodal level.
- The 2008 wind profile has been used as a base year.
- For 2012, wind farms are included as they are assumed to be commissioned i.e. Starting at 397.7MW and finishing at 494.6MW.
- For 2016, all wind farms with planning permission will be included from the beginning of the year. (910MW)
- SPS connected wind is included as 'allowable wind' i.e. The TSO does not need to pre-fault constrain this wind

Curtailement

- Curtailement studies will be carried out to ensure that at least 3 conventional generators will remain connected. This summates to ~420MW.
- An historic Moyle Profile is used to forecast future years. This analysis uses the same profile that was used in this year's Dispatch Balancing Costs Model.
- The same 2008 wind profile is used.

Curtailement

- The analysis assumes that the TSO will take measures to prevent curtailment. These measures equate to 200MW.

e.g. Demand = 1000MW
Conventional Gen + Moyle = 670MW
Remaining Demand for Wind = 330MW


Wind Forecast (2016) = 700MW
Potential curtailment = 370MW
TSO curtailment prevention = 200MW
Actual Curtailement figure = 170MW

- Where there is constraints and curtailment required at the same time, constraints will take precedence. Additional wind generation will be reduced if curtailment is greater than the constraint.
- Curtailement figures, constraint figures and combined generator reductions will be reported.

2012 Demand Vs Curtailment

- MAX = 1731MW
- AVERAGE = 1044MW
- MIN = 496MW

- MAX = 298MW
- AVERAGE = 6MW
- CAPACITY = 910MW



Reporting

- Each transmission modification is accounted for in the original Load flow studies for the relevant years
- Proposed Wind connections and demand forecasting are used for future years.
- This will allow developers to see what impact network upgrades will have on constraints.
- Curtailment figures, constraint figures and combined generator reductions will be reported.
- Brief commentary will be provided on each node.

Results

Omagh Generation Node					
Results	2012	2013	2014	2015	2016
Potential Energy (Mwh)	376251	-	-	-	201146
Constrained Energy (Mwh)	457	-	-	-	3649
Curtailed Energy (Mwh)	14541	-	-	-	27222
Constrained & curtailed Energy (Mwh)	14558	-	-	-	27482
Curtailement (%)	3.86%	-	-	-	13.53%
Constrained (%)	0.12%	-	-	-	1.81%
Constraint & Curtailement (%)	3.87%	-	-	-	13.66%

Results

Mid Antrim Generation Node					
Results	2012	2013	2014	2015	2016
Potential Energy (Mwh)	-	-	-	-	157146
Constrained Energy (Mwh)	-	-	-	-	2851
Curtailed Energy (Mwh)	-	-	-	-	21267
Constrained & curtailed Energy (Mwh)	-	-	-	-	21470
Curtailment (%)	-	-	-	-	13.53%
Constrained (%)	-	-	-	-	1.81%
Constraint & Curtailment (%)	-	-	-	-	13.66%

Disclaimer

Disclaimer

While all reasonable care has been taken in the preparation of this data SONI is not responsible for any loss that may be attributed to the use of this information. Prior to taking business decisions, interested parties are advised to seek separate and independent opinion in relation to the matters covered by this presentation and should not rely solely upon data and information provided here. Information in this presentation does not amount to a recommendation in respect of any possible investment.